

DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaiya Chowk, Opposite Khalsa sr. sec. school, Faridkot
dwtlfdk@gmail.com

To,

DOLPHIN PUBLIC SCHOOL
DOLPHIN PUBLIC SCHOOL WARA DARAKA ,FARIDKOT


No.: DWTL/FDK/2526/00438 Dated : 09/12/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 24/2025-26 Dated: 08/12/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 08/12/2025. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Faridkot

D/A : Test Report



Authorized Signatory
For, District water Testing Laboratory
Faridkot

DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanaia Chowk, Opposite Khalsa sr. sec. school, Faridkot
dwtfldk@gmail.com



TC-13893

TEST REPORT

Name & Address of Customer : DOLPHIN PUBLIC SCHOOL DOLPHIN PUBLIC SCHOOL WARA DARAKA ,FARIDKOT		Customer Reference No.	No : 24/2025-26 Dated : 08/12/2025
		Sample Submitted by	NARESK KUMAR
		Date of Sample Receipt	08/12/2025
		Analysis Starting Date	08/12/2025
		Analysis completion Date	09/12/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC103942500000588F	Sample Type :	Treated Water
Test Report No.:	DWTL/FDK/2526/00438	Date of Issue :	09/12/2025
Registration no.:	DWTL/FDK/REG2526/01465	Condition of Sample :	Sealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	DOLPHIN PUBLIC SCHOOL WARA DARAKA ,FARIDKOT / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Kot Kupura	District :	Faridkot
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.10@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	175	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Total Alkalinity (CaCO ₃)	20	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Total Hardness (CaCO ₃)	88	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	28.8	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	3.88	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	40	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

[Signature]
Headmistress
Dolphin Public School
Wara Daraka (Fdk.)
Aff. No. 1631073

2

Reviewed and Approved By

[Signature]

Mrs. Manju
Quality Manager
Authorized Signatory
For, District water Testing Laboratory
Faridkot

End of the Test Report